

**REVIEW OF THE USE OF NEW HIGH STRENGTH
STEELS IN CONVENTIONAL AND HRSG BOILERS
*R&D AND PLANT EXPERIENCE***

(Acronym: New Steels Review)

Final Report

ETD Report – No: 1045-gsp-40

Authors: I A Shibli, D G Robertson



European Technology Development Ltd - UK

September 2006

REVIEW OF THE USE OF NEW HIGH STRENGTH STEELS IN CONVENTIONAL AND HRSG BOILERS: R&D AND PLANT EXPERIENCE

(*Acronym:* New Steels Review)

ETD Report No. 1045-gsp-40

Report on Group Sponsored Project

European Technology Development Ltd.

2 Warwick Gardens, Ashted, Surrey, KT21 2HR, UK.

Tel: +44 (0)1372.802.555, +44 (0) 1372.229.162

Fax: +44 (0)1372.229.164

E-mail: etd@etd1.co.uk

<http://www.etd1.co.uk>

Disclaimer: Neither European Technology Development Ltd. (ETD) nor any one acting on behalf of ETD makes any warranty, expressed or implied in any way, with respect to the use of any information, data, advice or methodology disclosed in this report. ETD or any one acting on behalf of ETD do not accept any liabilities with respect to the use of, or for any damages resulting from the use of, any information, data, advice or methodology disclosed in this report.

Copyright: This Report has been produced by European Technology Development Ltd. (ETD) for the project sponsors, or any other body authorized in writing by ETD, only for use within their own organisation or on their clients' plant. No parts of this document may be photocopied or otherwise reproduced for distribution, sale, publication or use outside the sponsor's organisation without prior written permission of ETD.

CONTENTS LIST

	Page
MANAGEMENT OVERVIEW	7
<i>SECTION 1: PRINCIPAL ISSUES AND STUDY OBJECTIVES</i>	9
1.1. PRINCIPAL ISSUES	9
1.1.1. 9-12 Cr Martensitic Steels	9
1.1.2. Modified 2.25Cr Type Bainitic Steels (T/P23 and T/P24)	16
1.1.3. 12Cr Martensitic Steels	19
1.2. STUDY METHODOLOGY	20
<i>SECTION 2: GLOBAL USE OF HIGH STRENGTH STEELS</i>	21
2.1. USE OF P91	21
2.1.1. North American Plant Survey	21
2.1.2. European, African and Asian Plant Survey	25
2.1.3. Use in Japan and the Rest of the World	27
2.2. USE OF NEW W-BEARING 9Cr STEELS (P92, E911) IN EUROPEAN AND JAPANESE POWER STATIONS	30
2.3. USE OF T23/T24	32
2.4. USE OF 12Cr STEELS	34
<i>SECTION 3: PLANT FAILURES/CASE HISTORIES</i>	35
3.1 THICK SECTION CRACKING	35
3.1.1. Progress Energy Failures, USA	35
3.1.2. West Burton Failures (UK)	40
3.1.3. RWEnpower's Recent Plant Cracking Experience	43
3.1.4. Other Thick Section Component Failures	43
3.1.5. Other Vulnerability Issues	44

3.2. THIN SECTION TUBE FAILURES	44
3.2.1. Secondary Superheater Tube Failures in Hawaiian Electric Company's Plant (USA)	44
3.2.2. T91 Tube Failures due to Soot Blower Problems (USA)	46
3.2.3. Reverting to T22 Use Due to Weld Repair Problems with T91 Tubes (USA)	46
3.2.4. Tubing Failure in Japan	46
3.2.5. Replacement of T91 Tubing in Pakistan	47
3.2.6. Use of Other Materials for Tubing	47
3.3. DISSIMILAR METAL WELD (DMW) FAILURES	47
3.3.1. USA Failure in Station X	47
3.3.2. P91 to Inco625 Joint Failure	47
3.3.3. HECO Failure	48
3.3.4. Main Steamline Piping to Valve Dissimilar Weld Failure (USA)	48
	49
SECTION 4: HIGH TEMPERATURE MICROSTRUCTURAL, HEAT TREATMENT AND OXIDATION RELATED ISSUES	54
4.1. MICROSTRUCTURE AND HEAT TREATMENT ISSUES	
4.1.1. The Effect of Mo, W, Nb, V, N and Al Additions	54
4.1.2. Optimum Austenitising and Temperatures and Tempering Temperatures	57
4.2. OXIDATION ISSUES	
4.2.1. Type of Oxide Scales and Their Effect	59
4.2.2. Increase in Metal Temperature	59
4.2.3. The Possible Effect of Water Chemistry	64
4.2.4. Discussion on T91 Oxidation, Metal Loss and failure	66
4.2.5. Oxidation Resistance of Other High Strength Steels	66
4.2.6. Oxidation in Steam and Flue Gases	68
4.2.7. Other Oxidation Issues	68
	68
SECTION 5: WELDING, HEAT TREATMENT AND FORMING (BENDING ISSUES)	69
5.1. GENERAL BACKGROUND	
5.2. T/P91 WELDING	69
5.2.1. Welding Cycle Guidelines	70
5.2.2. Intermediate Heat Treatment	70
	73

5.2.3. Post Weld Heat Treatment (PWHT) and the Welding Consumables	74
5.2.4. Industry Experience with Welding P91	79
5.3. WELDING OF T/P92 AND E911	80
5.3.1. Development of Welding Consumables	81
5.3.2. Preheat and Post-Weld Heat Treatment	83
5.4. DISSIMILAR METAL WELDS	84
5.4.1. 9Cr to Ferritic Steel Welds	84
5.4.2. 9Cr to Austenitic Steel Welds	86
5.5. MODIFIED 2.25Cr BAINITIC STEELS (T/P23, T/P24)	87
5.5.1. General Aspects	87
5.5.2. Development of Welding Consumables	89
5.5.3. Heat Treatment	93
5.5.4. Dissimilar Metal Welds (DMWs)	95
5.6. WELDING P/T122	96
5.7. WELD REPAIR ISSUES	97
5.8. PIPE AND TUBE BENDING	100
5.8.1. Hot Bending	100
5.8.2. Cold Bending	100
SECTION 6: LONG TERM FAILURE MECHANISMS	102
6.1. CREEP RUPTURE	102
6.1.1. Strength Reduction Factors Predicted for P91 Welds	102
6.1.2. Base Metal Rupture Strength	104
6.2. CREEP-FATIGUE/HIGH TEMPERATURE FATIGUE ISSUES	112
6.2.1. Creep and Thermal Fatigue Cracking	112
6.2.2. Damage Accumulation Due to Creep-fatigue Interaction	113
6.2.3. Creep-Fatigue Capabilities of High Temperature Alloys	113
SECTION 7: LIFE/INTEGRITY ASSESSMENT, MONITORING AND INSPECTION ISSUES	118
7.1. MICROSTRUCTURE BASED INTEGRITY ASSESSMENT	118
7.1.1. Optical and Scanning electron Microscopy for Cavitation Measurement	119
7.1.2. Transmission Electron Microscopy	121
7.1.3. Use of Microstructural Parameters for Component Life Assessment	123
7.1.4. Area Fraction of Creep Voids	124
7.1.5. The Difference in Creep Void and Strength of the 9 and 12%Cr Steels	127

7.2. DETECTION OF CREEP DAMAGE BY INTELLIGENT PHASED ARRAY ULTRASONIC	129
7.3. ULTRASONIC NOISE METHOD	130
7.4. POTENTIAL DROP AS A DAMAGE MONITORING / MEASUREMENT TECHNIQUE	131 132
7.5. HARDNESS MONITORING AS AN INTEGRITY ASSESSMENT TOOL	136
SECTION 8: DISCUSSION	136
8.1. THICK WALL COMPONENTS	140
8.2. THIN WALL TUBING	141
8.3. IMPLICATIONS FOR DISSIMILAR METAL WELD FAILURES	142
8.4. CHOICE BETWEEN VARIOUS 9Cr MARTENSITIC STEELS	142
8.5. CREEP-FATIGUE INTERACTION AND THE DESIGN CODES	143
8.6. INSPECTION AND MONITORING STRATEGIES/TOOLS	143
8.7. INTEGRITY AND LIFE ASSESSMENT	144
8.8. WELDING ISSUES	146
SECTION 9: CONCLUSIONS	148
SECTION 10: IDEAS FOR FUTURE WORK FOR INTEGRITY/ LIFE ASSESSMENT	149
SECTION 11: REFERENCES	149

APPENDICES

	Page
Appendix A	158
Case Histories and Feedback from Utilities on Failures	
Appendix B	169
Modelling of P91 Oxide Scale Growth	
Appendix C	174
Feedback from Utilities on the Use of 9Cr Martensitic Steels	
Appendix D	179
Weld Repair Aspects	

Management Overview

This review deals with the status and use of modern high strength steels (in particular P91, P92, E911, P122 and T/P23, T/P24). This is the second review of its kind, the first was conducted in the year 2000. Both reviews were sponsored by international industry, from Europe, USA, Canada, Middle East and Asia. The first review had looked at the use of mainly 9Cr martensitic steels, the findings from research and very limited plant experience available at that time. This second review, in addition to the above, covers other high strength steels for high temperature application and the very important aspect of *integrity and life assessment* of these steels now that they have seen 15 to 20 years of service and cracking and failures are being reported from plants around the world.

A few years ago (at the time of the first P91 review) *failures* in e.g. P91 components were still relatively new and were attributed to weaker or suspect casts. A number of new failures have occurred since then and therefore interest in integrity/life assessment and monitoring of these components has become acute. This is especially so because the traditional NDE methods of replication and early damage detection in these steels have been found to be less than satisfactory and therefore there is a need to study, develop and establish new methodologies and techniques for life assessment of these steels. A number of new developments in this area have been reviewed and more promising techniques highlighted. The study has brought together research and plant experience from Japan, Europe and North America to throw light on potentially successful techniques that should be adopted.

The *welding and heat treatment* of many of these steels is critical in that small deviations from ideal practices can result in devastating consequences. In this era of competition, manufacturers and service providers are keen to save costs and therefore may look for lower cost sub-contractors for component fabrication and welding. However, some of these sub-contractors may not always be aware of the criticality of welding and heat treatment of these steels and incidents are known where this has resulted in problems with plant even before their fully fledged operation. Similarly choosing a *welding process* and *welding consumables* also requires the knowledge of what is available and the effect of these on the performance of the components. This issue has therefore been dealt with in some detail in this report and guidance provided.

Dissimilar metal welds is always a problem area in high temperature plant due to, amongst others, different heat treatment requirements for the two adjoining metals. In the case of the high Cr martensitic steels this situation becomes even more demanding and this has been discussed in this report together with the actual experience to date.

As the service life of P91 reaches the mid-life stage and the material shows signs of cracking and failure, it is important to understand the issues involved with *weld repairs*. This aspect has been researched particularly in Europe and is discussed in this review.

More recently, new light has been thrown on the *steam side oxidation* and this has proved to be not so good for steels, especially for superheaters, with less than about

10.5 to 11%Cr. The consequences of this in terms of tube life, damage to turbine blades etc. have been discussed in this report together with the alternatives available. This has been preceded by the science of various types of oxides that form on these steels and their behaviour and effect on the rise in metal temperature.

It is important to understand the process of creep strengthening in the new high strength steels and how their strength is affected by actual material chemical composition within the standards' specification, fabrication and exposure at high temperatures and pressures. Therefore this review discusses the *microstructure* details of these steels and their behaviour and integrity under creep and creep-fatigue (particularly for cycling plant) conditions.

The development of new low alloy bainitic steels such as T23 and T24 is now catching attention in many quarters. These were originally developed for boiler furnace tubing for ultra supercritical plants but can now be used, and indeed are being used, for superheater tubing for lower temperature boilers especially in HRSGs. Their main advantage is that thin sections can be welded without PWHT. Further developments are taking place regarding the use of these steels for thick section components. These aspects have been discussed in detail in this report.

Finally, it is important for the plant operators to know important *inspection and quality control* criteria when buying plants and components made from these steels. Here we have interviewed plant managers with most successful experience and the report provides guidance on what to ask for and look for when buying new plant or replacement components.

So much research has been going on these steels for the past ten years or so and so much has been published that it was important to synthesise this in to a useful and user friendly document which can be easily followed by plant engineers without getting lost in the details of the research itself. It was also important to bring together research findings and plant experience so that a comprehensive and comprehensible guide can be provided which relates to plant experience and works as a guide for plant manufacturers, service providers and plant operators. This report attempts to achieve these objectives.
